



UTTAR PRADESH POLLUTION CONTROL BOARD

Building. No TC-12V Vibhuti Khand, Gomti Nagar, Lucknow-226010

Phone:0522-2720828,2720831, Fax:0522-2720764, Email: info@uppcb.com, Website: www.uppcb.com

CONSENT ORDER

Ref No. -

145544/UPPCB/Lucknow(UPPCBRO)/CTO/water/LUCKNOW/2021

Dated : 24/12/2021

To ,

Shri SANDEEP KAPOOR

M/s Lucknow Health City Trauma Centre and Super Speciality Hospital Pvt Ltd
NH A and B/2, Vijay khand 2, gomti Nagar, Lucknow,LUCKNOW,
LUCKNOW

Sub : Consent under Section 25/26 of The Water (Prevention and control of Pollution) Act, 1974 (as amended) for discharge of effluent to M/s. Lucknow Health City Trauma Centre and Super Speciality Hospital Pvt Ltd

Reference Application No :14490632

Dated :24/12/2021

1. For disposal of effluent into water body or drain or land under The Water (Prevention and control of Pollution) Act,1974 as amended (here in after referred as the act) M/s. Lucknow Health City Trauma Centre and Super Speciality Hospital Pvt Ltd is hereby authorized by the board for discharge of their industrial effluent generated through ETP for irrigation/river through drain and disposal of domestic effluent through septic tank/soak pit subject to general and special conditions mentioned in the annexure ,in reference to their foresaid application .
2. This consent is valid for the period from 23/12/2021 to 31/12/2023 .
3. In spite of the conditions and provisions mentioned in this consent order UP Pollution Control Board reserves its right and powers to reconsider/amend any or all conditions under section 27(2) of the Water (Prevention and Control of Pollution) Act, 1974 as amended .

This consent is being issued with the permission of competent authority .

For and on behalf of U.P. Pollution Control Board

Dr Ram Karan Digitally signed by Dr Ram Karan
Date: 2021.12.24 08:23:16 +05'30'
Regional Officer Lucknow

Enclosed : As above
(condition of consent):

Copy to: CEO-5 UPPCB VIBHUTI KHAND LUCKNOW

Dr Ram
Karan Digitally signed by Dr
Ram Karan
Date: 2021.12.24
08:23:43 +05'30'
Regional Officer Lucknow

U.P. POLLUTION CONTROL BOARD, LUCKNOW

Annexure to Consent issued to M/s.Lucknow Health City Trauma Centre and Super Speciality Hospital Pvt Ltd vide

Consent Order No. 14490632/ Water

Dated : 24/12/2021

CONDITIONS OF CONSENT

1. This consent is valid only for the approved production capacity of Lucknow Health City Trauma Centre and Super Speciality Hospital Pvt Ltd, NH A and B/2, Vijay Khand 2, Gomti Nagar,, LUCKNOW, Health -care Establishment (as defined in BMW Rules) for 100 Bedded Hospital with CTO valid up to 31.12.2023.

2. The quantity of maximum daily effluent discharge should not be more than the following :

Effluent Discharge Details			
S.No	Kind of Effluent	Maximum daily discharge,KL/day	Treatment facility and discharge point
1	Domestic	10 KLD	STP
2	Industrial	10 KLD(Hospital Effluent)	ETP

3. Arrangement should be made for collection of water used in process and domestic effluent separately in closed water supply system. The treated domestic and industrial effluent if discharged outside the premises, if meets at the end of final discharge point, arrangement should be made for measurement of effluent and for collecting its sample. Except the effluent informed in the application for consent no other effluent should enter in the said arrangements for collection of effluent. It should also be ensured that domestic effluent should not be discharged in storm water drain .

- 4(a) The domestic effluent should be treated in treatment plant so that the should be in conformity with the following norms dated treated effluent .

Domestic Effluent		
S.No	Parameter	Standard
1	Total Suspended Solids	As per E.P Act
2	BOD	As per E.P Act
3	COD	As per E.P Act
4	Quantity of Discharge	10 KLD

- 4(b). The industrial effluent should be treated in treatment plant so that the treated effluent should be in conformity with the following norms. .

Industrial Effluent		
S.No	Parameter	Standard
1	Total Suspended Solids	As per E.P Act
2	BOD	As per E.P Act
3	COD	As per E.P Act
4	Quantity of Discharge	10 KLD

5. Effluent generated in all the processes, bleed water, cooling effluent and the effluent generated from washing of floor and equipments etc should be treated before its disposal with treated industrial effluent so that it should be according to the norms prescribed under The Environment (Protection) Act,1986 or otherwise mandatory .
6. The other pollutant for which norms have not been prescribed, the same should not be more than the norms prescribed for the water used in manufacturing process of the industry .
7. The method for collecting industrial and domestic effluent and its analysis should be as per legal Indian standards and its subsequent amendments/standards prescribed under The Environment (Protection) Act, 1986.

8. The treated domestic and industrial effluent be mixed (as per the provisions of Condition No. 2) and disposed of on one disposal point. This common effluent disposal point should have arrangement for flow meter/V Notch for measuring effluent and its log book be maintained .
9. The Unit will file the renewal application at least 2 months prior to the expiry of this Order.

Specific Conditions:

1 M/s Lucknow Health City Trauma Centre and Super Speciality Hospital Pvt Ltd, NH A and B/2, Vijay Khand 2, Gomti Nagar,, LUCKNOW, Health -care Establishment (as defined in BMW Rules) for 100 Bedded Hospital with CTO valid up to 31.12.2023. For renewal of the consent, application in the prescribed form shall be submitted through the web portal of the Board for Online Consent Management & Monitoring System 2 months prior to the date of expiry.

2. This consent is granted subject to the power of the Board to review and make variation in or revoke any of the conditions as the Board deems fit as per the relevant Acts/Rules.

3. The applicant shall comply with the instructions that the Board may issue from time to time regarding prevention and control of air, water, land and sound pollution.

4. No change or alteration of the unit/establishment is to be made without the prior written permission of the Board. Any change in the particulars furnished and/or in the identity of the occupier/authorized person is to be intimated to the Board forthwith.

5. Arrangements for collection, segregation, storage, handling and disposal of solid Waste and BMW shall be provided and maintained properly as per the rules of SWM 2016 and BMW Rules 2016 and will develop their own method for the disposal of solid wastes.

6. This consent is granted on the basis of the other documents furnished by the applicant. If the statement furnished in document is found false or in the case of noncompliance of integrated consent to operate conditions the consent issued will be withdraw/cancelled.

7. (A). Any change in personnel, equipment or working conditions as mentioned in the consents form/order should immediately be intimated to the Pollution Control Board Lucknow.

7. (B). If at any time, it is observed that effluent fails to confirm to the limits prescribed, consent will be withdrawn prohibiting the unit to manufacture either existing or new products.

7. (C). The applicant shall submit separate application for obtaining Consent for Operation/ Renewal under Water (Prevention and Control of Pollution) Act, 1974, before 60 days of expiry of validity period of Consent.

8. The Hospital shall provide the compliance report of the consent conditions to this office every three monthly.

9. The Hospital shall comply the BMW Rules 2016 and submit the Compliance Report.

10. The Hospital shall provide the records/documents/log book regarding natural gas, electricity and water consumption etc and also co-operate the visiting officers of the Board.

11 The Hospital shall obtain permission from State Ground Water Authority for abstraction of ground water and send its compliance report.

12. The Hospital will have to install or adopt rain water harvesting system on the premises as per map approved by concerned Authority to maintain a ground water level by charging rain water. Pre and Post-monsoon maintenance of rain water harvesting pit shall be done annually.

13. The Hospital shall provide facility for collection of samples of effluent, air emissions and hazardous waste to the Board staff at the terminal or designated point and shall pay to the Board for the services rendered in this behalf.

14. Balance consent fee if any will be payable within 15 days of time from the issue of this Consent.

15. This CTO is valid for the effluent generation of 10.0 KLD and Sewage generation of 10.0 KLD. If the generation of Effluent/sewage is more than above then this CTO will not be valid.

16. The Hospital shall ensure proper disposal of Domestic/Effluent Waste through installed capacity STP/ETP and will send the analysis report from approved laboratory every three monthly basis.

17 Hospital will install magnetic flow meter at the Inlet/Outlet of the STP/ETP and will maintain the log book and will submit it trimonthly.

Issued with the permission of competent authority .

For and on behalf of U.P. Pollution Control Board .

Dr Ram Karan Digitally signed by Dr Ram Karan
Date: 2021.12.24 08:24:14 +05'30'
Regional Officer Lucknow